

5590 N MARINE DR
03-141515-000-00-SD

2298941

Site Development Permit

Near St. Johns Land Fill

Issued: 8/8/03

Existing Commercial Site/Landslide/Slope Repair

Occupancy: Const. Type:

Near St. Johns Land Fill

Inspection:

200 Pre-Construction EC

(503) 797-1515

Call Date/Time: 7/19/2004 13:31:5

Requested Date/Time: 7/21/04

EC1 EC3

Applicant: METRO *ELAINE STEWART*

(503) 797-1515

Owner: METRO

(503) 731-7827

Contractor: To Bid

Most Recent Inspections

MITIGATION FOR DISTURBING EARTH BERM PER LU 02-113706-EN

City of Portland OPDR

INSPECTION REPORT

IVR Number: 2298941

Inspection Code: 200

1	Approved
2	Partially Approved
3	Approved with Corrections
4	Rollover/Missed
X 5	Not Approved
6	Consultation Completed
7	Requested in Error
8	Posted in Error

No Access	1
Stop Work Order Issued	2
Not Ready	3
Could Not Locate	4
See Correction Notice on Job Site	5 X
No Plans on Job (?)	6 X
No Permit Card on Job	7
Fees Owed	8
Subcontractor Label Missing	9
Cancelled by Customer	0

Confirmation: #885314	Inspector/Date/Time/Phone Mary King 7-21-04	503 823 7321
-----------------------	--	--------------

cell 503 823 6391

1) Install storm drain inlet filters in parking lot catch basins

2) Provide a gravel construction entrance

3) Install sediment fence along construction entrance/site entry on side near lake pond. Patch/repair existing sediment fence where needed

Fees Paid

Erosion Control	\$179.00	Site Develop. Permit	\$242.51
Building Permit St. Sur.	\$19.40	Site Dev. Plan Check	\$157.63
Planning Plan Check CO	\$97.00	Zoning Inspection Fee	\$68.00
BES Source Control Plan Review	\$24.00		